

STATEMENT ACCOMPANYING FORM-A

1. Door number of the building : Door No: 284/1
2. Location (Street No; Ward No : S.F. No.: 424/2B,
Name of place, i, e.,
Corporation/Municipality/ "GANDHI PUBLIC SCHOOL"
Panchayat union/Township/ Perumapatty Road
Cantonment) N.Kandampalayam, Nallur Village,
Paramathi-Velur Taluk,
Namakkal District.

3. Plinth Area/Year of Construction :

S. No.	Name of the Building with Description	Year of Construction With age	Future Life of Building in Years	Plinth area of the Building in Sq.Ft	Approximate cost of Construction Rs.	Floor Area of the Building in Sq.Ft
<u>RCC ROOF BUILDING</u>						
<u>BLOCK -I</u>						
1.	Ground Floor (including portico, corridor & staircase)	2002 (21 Years)	39 Years	10,164.25	81,31,000.00	----
2.	First Floor (including corridor & staircase)	2002 (21 Years)	39 Years	9,449.25	70,87,000.00	----
3.	Second Floor (including corridor & staircase)	2002 (21 Years)	39 Years	9449.25	75,59,000.00	----
<u>BLOCK-2</u>						
4.	Toilet Block	2002 (21 Years)	39 Years	988.25	6,92,000.00	----
<u>BLOCK-3</u>						
5.	Toilet Block	2002 (21 Years)	39 Years	395.60	2,37,000.00	----

4. Purpose for which the Building is being used or proposed to be used : Class Rooms & Toilet For School Purpose
5. Purpose for which the Building has hither to been used : - do -



6. Details of construction of the Building : Framed Structure R.C Column Footing,
(Particulars of the foundation Soil, Brick Masonry in Cement Mortar
Specification of the various parts under) RCC Roof, Cement Flooring

a) Foundation : R.C.C. Column in C.M

b) Basement : - do -


c) Super Structure : Brick Masonry and Plastered with
Cement Mortar

d) Floor and Roof : Cement Flooring & RCC Roof

7. Period for which license : 3 Years
is required from 01.06.2024 To 31.05.2027

8. Number of persons to be : Students - 1200 No's
accommodated +
Staffs - 30 No's

Date: 29.01.2024


Signature of the Engineer

L.N. Er. A. VENKATACHALAM, ME, M.Sc., (RV) MIE, FIV,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A,
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024


Signature of the Owner of the building

FORM - B

Form of certificate of structural soundness under sub-section (4) of section 4 of the Madras public Buildings (licensing) Act 1965 (Madras act 13 of 1965) referred to in rule 4 of the Madras public buildings (licensing) Rules 1965.

I certify that I have Inspected the building mentioned in the statement below and I have satisfied myself that the building is structurally sound to be used as a public building for the purpose noted in the statement. The Structural Soundness of the building has been verified in to account the loading as per the latest Indian standard. A license to the period of 3 Years from **01.06.2024 To 31.05.2027.**

Date: 29.01.2024


Signature of the Engineer
Ln. Er. A. VENKATACHALAM, ME, M.Sc. (RV) MIE, FIV.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A, M
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024


STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building (door no, street & name of place)	Age of the Building	Purpose for the building is certified for use	Period for which the building will be Structurally Sound	No. of persons to be accommodated	Remarks
"GANDHI PUBLIC" SCHOOL" D.No:284/1, Perumapatty Road, N.Kandampalayam, Nallur Village, Paramathi Velur T.K., Namakkal District.	2002 (21 Years)	Class Rooms, & Toilet for School Purpose	3 Years from 01.06.2024 To 31.05.2027	Students- 1,200 No's + Staff's 30 No's	----

This certificate will not hold good in case of natural calamities such as fire, flood and earthquake.

This certificate is not valid if the Applicant makes any Additions (or) modifications without prior Approval.

Date: 29.01.2024


Signature of the Engineer
Ln. Er. A. VENKATACHALAM, ME, M.Sc. (RV) MIE, FIV.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A, M
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024

DECLARATION


I **A.VENKATACHALAM** Son of **M.ATHIYAPPA GOUNDER** Residing at 29/57, Salem Road, Near K.S. Theater, Namakkal do hereby declare that I posses the qualification and experience specified in the table to Rule 2 of the public Building (licensing) Rules 1966 for issuing the certificate of structural soundness of the building covered by this certificate.

- | | |
|--|---|
| i) Name and address
(in block letters) | : A. VENKATACHALAM
ARRUL ASSOCIATES,
29/57, Salem Road,
Near K.S. Theater,
Namakkal. |
| ii) Engineering qualification | : M.E., (Structural) M.I.E., F.I.V.,
Chartered Engineer
Government Approved Engineer,
Registered Valuer. |
| iii) Numbers of years of
experience and nature there of | : 34 Years of practical experience in
all types of construction and valuation works |

DISTRICT PANEL ENGINEER CLASS- IA

Proceeding of the District Collector, Namakkal & Chennai Chief Engineer (General) Public Works Department, Lt No.AEE/T1/AE I/60992/2010. Dt.27.07.2010

Date: 29.01.2024


Signature of the Engineer
Ln. Er. A. VENKATACHALAM, ME., M.Sc., (RV) MIE., F.V.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A, APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001,
Cell : 98427 57507, 98427 33024

CERTIFICATE OF STABILITY

FORM – C

Form of certificate of structural soundness under sub section – 4 of the Tamilnadu Public Building (licensing) Act (Tamil Nadu Act 13 of 1965 referred to in rule of the Tamilnadu public Building (Licensing) rule 1965.

I certify that I have inspected the building mentioned in the statement and furnish below its salient technical features.

1) Foundation:

- | | | |
|--|---|--------------------------------------|
| i. Depth below ground level | : | 1.80 M |
| ii. Nature of soil met with at foundation level | : | Hard Gravel Soil below ordinary Soil |
| iii. Pressure at foundation | : | RCC Roof Building - 18.72 tones/sqm |
| iv. Probable safe bearing capacity of the) of the soil met with at foundation) | : | 30 tones/sqm |

2) Superstructure:

- | | | |
|--|---|---|
| i. Maximum stress in the most critical section of masonry and concrete | : | Brick Masonry in Cement Mortar
RCC Roof Building – 22.45 tones/sqm |
| ii. Nature of masonry and concrete and its safe permissible stress | : | Brick Masonry and Plastered with Cement Mortar = 40 tones/sqm.
Framed Structure = 15 N/Sqm |

The Structural Soundness of the building has been verified by me with reference to ISI loading standards 875 (latest version) and other relevant Indian standards code of practice and declare that the building for the purpose noted in the statement, A license may be granted for the period of 3 Years from **01.06.2024 To 31.05.2027**.

Date : 29.01.2024


Signature of the Engineer
Ln. Er. A. VENKATACHALAM, ME., M.Sc., (RV) MIE., FIV.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A, &
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024


STATEMENT TO ACCOMPANY THE CERTIFICATE OF STRUCTURAL SOUNDNESS

Location of the Building Door no, street, and Name of place	Age of the Building	Number of Stories	Short description of Structures Steel/RCC Framed/ Load bearing Masonry	Purpose for which the Building is certified to Use	The Period for which the building will be Structurally sound	Number of persons to be accommodated
(1)	(2)	(3)	(4)	(5)	(6)	(7)
"GANDHI PUBLIC SCHOOL" D.No. 284/1, Perumapatty Road, N.Kandampalayam Nallur Village, Paramathi-Velur Taluk, Namakkal District.	2002 (21 Years)	Ground, First & Second Floor	RCC Framed Structure	Class Rooms, Toilet For School Purpose	3 Years from 01.06.2024 To 31.05.2027	Students- 1,200 No's + Staffs – 30 No's

This certificate will not hold good in case of natural calamities such as fire, flood and Earthquake.

This certificate is not valid if the Applicant makes any Additions (or) modifications without prior Approval.

Date: 29.01.2024



Signature of the Engineer

Ln.Er.A.VENKATACHALAM, M.E., M.Sc., (FIV) MIE, FIV.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A, 
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024


FORM – 'E'

Form of Report to be made to the Competent Authority by Inspecting Authorities or Officers appointed Under Section 238 of the Madras Public Building (Licensing Act 1965 Madras Act 13 of referred to in rule 7 of the Madras Public Building (Licensing) Rule 1966.

- | | |
|---|--|
| 1. Name and designation of Inspecting authority or Officer appointed of having Jurisdiction Under Other act of Law. | Er. A. VENKATACHALAM.,
District Panel Engineer- Class 1A |
| 2. Location of the Building Inspected (Door No. Street., Name of Place i.e. Municipal Corporation/ Municipality Union/Township/Cantonment | "GANDHI PUBLIC SCHOOL",
S.F.No: 424/2B,
D.No:284/1, Perumapatti Road,
N. Kandampalayam, Nallur Village,
Paramathi-Velur Taluk,
Namakkal District. |
| 3. Date of Inspection | 29.01.2024 |
| 4. Purpose for which the Building is Used | Class Rooms for School Purpose |
| 5. Nature of defects Noticed | NIL |
| 6. Suggestions for rectifying defects | NIL |
| 7. If in a dangerous Condition immediate Steps recommended to be taken | NIL |

PLACE : NAMAKKAL

DATE : 29.01.2024


Signature of the Engineer

Ln. Er. A. VENKATACHALAM, ME., M.Sc., (RV) MIE., FIV.,
CHARTERED ENGINEER, REGISTERED VALUER-04/05-06
DISTRICT PANEL ENGINEER CLASS -1A, &
APPROVED VALUER FOR BANKS,
ARRUL ASSOCIATES,
29/57, Salem Road, Namakkal-637 001.
Cell : 98427 57507, 98427 33024

Proceedings of the District Collector, Namakkal
Present: Tmt.S.Madumathi, I.A.S.

Roc No 30642/2010/C2

Dated: 03.01.2011

Sub:Tamilnadu Public Buildings-(Licensig) Rules 1965-
Drawing of Panel of Registered Engineers under Rule 11-
Application of Thiru Er . A.Venkat achalam,M.E.,MIE .,
FIV., to include his name in the panel-Ordered.

Read:1) Application of Er.A.Venkatachalam, M.E., MIE.,
FIV., Dated: 21.01.2007.
2)Chennai Chief Engineer (General) P.W.D Lr No
AEE/TI/AE I / 60992/2010. Dated : 27.07.2010.


ORDER:

The Name of Er A.Venkatachalam M.E , MIE , FIV., Chartered Engineer, Arrul, Associates, No1,Paramathi Road,Opp. to Municipal office, Namakkal Taluk,Namakkal District is included in the panel of private practicing registered Engineers of Namakkal district maintained in this office with the approval of the Board of Engineers as laid down under the Rule 11 of the Tamilnadu Public Buildings (licensing) Rules, 1966 for the issue of structural soundness certificate for public buildings under Tamil Nadu Public Buildings (Licensing) Act, 1965.

2) He is registered under the category of Class IA (one A) (The value of building work costing more than 30 lakhs).

(Sd)S.Madumathi
District Collector,
Namakkal.

/True Copy/


12/1/2011
For Collector
Namakkal

To
Er.A.Venkatachalam,M.E, MIV, FIV,
Arrul Associates,
No,1,Paramathy Road,
Opp.to Municipal Office,
Namakkal Taluk,
Namakkal District.

Copy to the All Tahsildars.
Copy to 'C2' for stock File.

