



**TAMILNADU FIRE AND RESCUE SERVICE DEPARTMENT
FIRE AND RESCUE STATION - TIRUCHENGODE**

S.No : 22/2026

Date: 12.06.2026

R.C.No : 260/IV/2026

No objection Certificate

Sub: Tamil Nadu Fire & Rescue Services – Namakkal District – Use of Places and trade for purpose involving risk from fire – No objection Certificate – Issued.

Ref: 1.Govt G.O. No:122 school Education (2) Department, Dated: 14.09.2004
2.Govt G.O. No:123 school Education (2) Department, Dated: 14.09.2004
3.Application from The Correspondent, Gandhi Public School (CBSE), Dated : 09.06.2026

With reference to the letter cited above, Premises **M/S.GANDHI PUBLIC SCHOOL (CBSE)** at Situated at D.No: 284/1, S.F.No: 424/2B, Perumapatti Road, N.Kandampalayam, Nallur village, Paramathi Velur Taluk, Namakkal District – 637203 was inspected by Mr.K.Karikalan, Station Fire Officer on 12.06.2026. There is no objection from the Fire Service Point of view to license such below conditions as may be Prescribed. This license is valid for **THREE YEARS** from 12.06.2026 to 11.06.2029 and Should be renewed on 12.06.2029.

CONDITIONS

1. All firefighting equipment should always be kept in good working condition at all times and it should be as per the NBC 2016 part -IV maintained well and working in good condition. The trained personnel should always be available to operate the systems in case of any emergency.
2. Fire extinguishers should be installed and maintained as per IS 2190:2010
3. Mock drill should be periodically conducted.
4. Any addition and/or alteration of a permanent or temporary structure should be intimated to the Fire and Rescue Service Department.
5. Fire order / contingency plan / evacuation plan should be prepared and displayed in each floor at prominent places and Do's & Don'ts boards should be displayed.
6. Emergency fire exit, staircases and doors should not be obstructed
7. Good housekeeping should be maintained and dumping of waste materials anywhere should be avoided.
8. All the electrical equipment, fitting, accessories and Wiring system should be maintained. As per IS 1646: 1997 Code of Practice for Fire Safety of Building (General) Electrical Installation should be followed.



[Signature] 12/06/26
**STATION OFFICER
FIRE AND RESCUE STATION
TIRUCHENGODE - 637205**

To,
M/s. The Correspondent,
Gandhi Public School (CBSE),
Perumapatti Road, N.Kandampalayam, Nallur village,
Paramathi Velur Taluk, Namakkal District – 637203

Copy: District Officer, Fire & Rescue service, Namakkal District.